



AQUA PRO-TECH LABORATORIES
 Certified Environmental Testing

Client: Benway School
 620 Valley Rd
 Wayne, NJ 07470

APL Order ID Number: 2020078
 Collected : 02/02/2022 0:00
 Received: 02/02/2022

Contact:
 Client Project: Water Test 2022

Contact: 02/18/2022 11:47
 Customer Service Rep: Tony Tudda

Analytical Results Summary

Sample Number	Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
2020078-01	Drinking Water		Kitchen D Sink						
Total Metals									
Copper		EPA 200.8	2/17/22 19:09	2/17/22 19:09	0.104			0.00200	mg/L
Lead		EPA 200.8	2/17/22 19:09	2/17/22 19:09	0.00298			0.00200	mg/L
2020078-02	Drinking Water		Faculty Bathroom						
Total Metals									
Copper		EPA 200.8	2/17/22 19:11	2/17/22 19:11	0.0858			0.00200	mg/L
Lead		EPA 200.8	2/17/22 19:11	2/17/22 19:11	< 0.00200	U		0.00200	mg/L
2020078-03	Drinking Water		Nurse Office						
Total Metals									
Copper		EPA 200.8	2/17/22 19:14	2/17/22 19:14	0.101			0.00200	mg/L
Lead		EPA 200.8	2/17/22 19:14	2/17/22 19:14	< 0.00200	U		0.00200	mg/L
2020078-04	Drinking Water		1st Floor Boys Room						
Total Metals									
Copper		EPA 200.8	2/17/22 19:16	2/17/22 19:16	0.135			0.00200	mg/L
Lead		EPA 200.8	2/17/22 19:16	2/17/22 19:16	< 0.00200	U		0.00200	mg/L
2020078-05	Drinking Water		1st Floor Girls Room						
Total Metals									
Copper		EPA 200.8	2/17/22 19:18	2/17/22 19:18	0.150			0.00200	mg/L
Lead		EPA 200.8	2/17/22 19:18	2/17/22 19:18	< 0.00200	U		0.00200	mg/L

Brian Wood
 Laboratory Director

Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
--------------------------	--------	----------	----------	--------	------	-----	----	-------

2020078-06 Drinking Water 2nd Floor Girls Room

Total Metals

Copper	EPA 200.8	2/17/22 19:21	2/17/22 19:21	0.100			0.00200	mg/L
Lead	EPA 200.8	2/17/22 19:21	2/17/22 19:21	< 0.00200	U		0.00200	mg/L

2020078-07 Drinking Water 2nd Floor Boys Room

Total Metals

Copper	EPA 200.8	2/17/22 19:54	2/17/22 19:54	0.110			0.00200	mg/L
Lead	EPA 200.8	2/17/22 19:54	2/17/22 19:54	< 0.00200	U		0.00200	mg/L

2020078-08 Drinking Water Art Room

Total Metals

Copper	EPA 200.8	2/17/22 19:56	2/17/22 19:56	0.0794			0.00200	mg/L
Lead	EPA 200.8	2/17/22 19:56	2/17/22 19:56	< 0.00200	U		0.00200	mg/L

FootNotes

RL - Reporting limit
 MDL - Minimum detection limit
 ND, U - Indicates compound analyzed for but not detected
 J - Indicates estimated value

B - Indicates compound found in associated blank
 E - Concentration exceeds highest calibration standard
 D - Indicates result is based on a dilution
 P - Greater than 25% diff. between 2 GC columns
 H - Indicates a Hold Time violation
 D1 - Sample was Decanted (Dissolved)

Brian Wood
Laboratory Director



CHAIN OF CUSTODY

APL 2020078

AQUA PRO-TECH LABORATORIES



TEL: 973.227.0422
FAX: 973.227.2813

CONTAMINATION LEVEL

HIGH MEDIUM LOW

CLIENT: <u>BENWAY SCHOOL</u>	SEND REPORT TO: <u>BENWAY SCHOOL</u>
ADDRESS: <u>620 Valley Rd</u>	ADDRESS: <u>620 VALLEY RD</u>
<u>WAYNE NJ 07476</u>	<u>WAYNE NJ 07476</u>
PHONE: <u>973 633 3837</u>	PHONE: <u>973 633 3837</u>
E-MAIL: <u>Cminigoia@BENWAY SCHOOL NJ.COM</u>	FAX:
PROJECT NAME: <u>WATER TEST 2022</u>	SEND INVOICE TO: <u>BENWAY SCHOOL</u>
PROJECT MGR:	ADDRESS: <u>620 VALLEY RD WAYNE NJ 07476</u>
PROJECT or PO #:	SAMPLED BY:

TURN-AROUND TIME

- APL STANDARD 2 weeks
- RUSH (choose one below)
 - 24 hr. date & time required _____
 - 48 hr. date & time required _____
 - 72 hr. date & time required _____
 - 1 week _____

- | | |
|---|---|
| REPORT FORMAT | ELECTRONIC FORMAT |
| <input type="checkbox"/> RESULTS ONLY | <input type="checkbox"/> EMAIL DELIVERY |
| <input type="checkbox"/> NJ DEP REDUCED | <input type="checkbox"/> HAZSITE EDD |
| <input type="checkbox"/> NJ DEP FULL | <input type="checkbox"/> EXCEL |
| <input type="checkbox"/> STATE FORMS/E2 REPORTING | SRP# _____ |
| PWSID# _____ | |

MATRIX ABBREVIATIONS: D - DRINKING WATER G - GROUNDWATER W - WASTEWATER S - SOIL SL - SLUDGE C - CONCRETE L - LAKE

APL Lab ID#	Sample Source: Field ID	Date	Time	Sample Type		M A T R I X	No. of Bottles	Preservative	Analysis Requested
				G R A B	C O M P				
B1 2022	Kitchen D SINK						1		Lead Testing
B3 2022	FACULTY BATHROOM						1		Lead Testing
B4 2022	Nurse BATHROOM OFFICE						1		Lead Testing
B5 2022	1st floor BOYS ROOM						1		Lead Testing
B6 2022	1st floor Girls room						1		Lead Testing
B7 2022	2nd floor Girls room						1		Lead Testing
B8 2022	2nd floor BOYS ROOM						1		Lead Testing
B2 2022	Art room						1		Lead Testing

RELINQUISHED BY (Print) <u>Donnie THOMAS</u>	DATE <u>2/2/22</u>	RECEIVED BY (Print) <u>Blitt V</u>
Signature <u>[Signature]</u>	Time <u>10:15AM</u>	Signature <u>[Signature]</u>
RELINQUISHED BY (Print)	DATE	RECEIVED BY (Print)
Signature	Time	Signature
RELINQUISHED BY (Print)	DATE	RECEIVED BY (Print)
Signature	Time	Signature
COMMENTS/SPECIAL INSTRUCTIONS <u>PAID</u> <u>CHECK # 7276 9V</u> <u>\$1200.00</u>	Cooler Temp. upon receipt at lab <u>3.6 °C</u>	